

Amendment Number 1 to

**Bidding Document for Procurement of:
Steel Poles for power distribution
network**

Issued on : 25th March, 2017

ICB No : C1-G3

Purchaser : Ministry of Electricity and Energy

Country : Myanmar

- 1) The following amendments are made to **Technical Specification TS-CO-08**, in the Bidding Document:

Changed from	Revised to
Clause 5.8, Table 5.7, Bending Moment @ GL (kNm) For SP 10 (10 m steel pole) 44.3	Clause 5.8, Table 5.7, Bending Moment @ GL (kNm) For SP 10 (10 m steel pole) 42.7
Clause 5.8, Table 5.7, Minimum Steel Thickness For SP 10 (10 m steel pole) 2.54 mm For SP 12 (12 m steel pole) 2.54 mm	Clause 5.8, Table 5.7, Minimum Steel Thickness For SP 10 (10 m steel pole) 4 mm For SP 12 (12 m steel pole) 4 mm
Clause 5.8, Table 5.7, Description of goods Horizontal load 600 mm from the top(kg)	Clause 5.8, Table 5.7, Description of goods Horizontal load 250 mm from the top(kg)
Drawing of Tubular Steel Pole 10 M Parameter item No 5. Thickness 2.54 mm	Drawing of Tubular Steel Pole 10 M Parameter item No 5. Thickness 4 mm
Drawing of Tubular Steel Pole 12 M Parameter item No 5. Thickness 2.54 mm	Drawing of Tubular Steel Pole 12 M Parameter item No 5. Thickness 4 mm
Clause 5.1(c) , The tubes shall overlap not less than three (3) times the overall diameter of the larger of the tubes forming the joint	Clause 5.1(c) , The minimum lap joint length should be (1.5) times the maximum inside diameter of the larger of the tubes forming the joint.

- 2) The following amendments are made to **Technical Schedule TS-CO-08-S** , for Pre-stressed Spun Concrete Poles in the bidding document:

Changed from		Revised to	
1	2	1	2
No.	Item	No.	Item
11	Thickness of Steel Pole (min)	11	Thickness of Steel Pole (min)
	10 M, Type (2.54 mm)		10 M, Type (4 mm)
	12 M, Type (2.54 mm)		12 M, Type (4 mm)
14	Design bending moment @GL	14	Design bending moment @GL
	10M, Type		10M, Type
	44.3 kNm		42.7 kNm
15	Horizontal load	15	Horizontal load
	(600 mm from the top)		(250 mm from the top)

- 3) All items covered in the Amendments column in the table shall also be treated as amendments to the Bidding Document.